

Property	Unit	Minimum	Maximum	Test method	
Cetane number	-	52,9	-	EN ISO 5165	
Density at 15 °C	kg/m ³	765.00	800.00	EN ISO 3675	
Flash Point	°C	>55	-	EN ISO 22719	
Carbon residue on 10% distillation residue	% m/m	-	0,3	EN ISO 10370	
Ash content	% m/m	-	0,0	EN ISO 6245	
Water content	mg/kg	-	200	EN ISO 12937	
Total contamination	mg/kg	-	24	EN ISO 12662	
Copper strip corrosion (3 hrs. at 50 °C)	Rating	Class 1		EN ISO 2160	
Oxidation stability	g/m ³	-	25	EN ISO 12205	
	h	20	-		
Manganese content	mg/l	-	20	EN ISO 16136	
Total aromatics	% m/m	-	1,1	EN ISO 12916	
Sulfur content	mg/kg	-	5,0	EN ISO 201846	
Lubricity, corrected wear scare diameter (wsd 1,4) at 60 °C	µm	-	460	EN ISO 12156-1	
Viscosity at 40 °C	mm ² /s	1.9	4,5	EN ISO 3104	
Fatty acid methyl ester (FAME) content	% v/v	-	7,0	EN ISO 14078	
Distillation	% (v/v) recovered at 250 °C	% v/v	-	<65	EN ISO 3405
	% (v/v) recovered at 350 °C	% v/v	85	-	
	95% (v/v) recovered at	°C	-	360	
CFPP	Summer*	°C	-	0	EN 116
	Intermediate**	°C	-	-5	
	Winter***	°C	-	-20	

* Summer: May 1st - September 30th

** Intermediate: October 1st - November 15th / March 1st - April 30th

*** Winter: November 16th - Februari 28th

Edition: 2019

Version: 1