

PRODUCTBLAD

PETROLEUM (KERO B)

Property	Unit	Minimum	Maximum	Test method	
Appearance	-	C/B		ASTM D 4176	
Density at 15 °C	kg/m ³	780,0	820,00	EN ISO 3675	
Colour	-	Yellow	-	ASTM D 1500	
Sulfur content	mg/kg	-	100	EN ISO 20846	
Flash Point	°C	37,0	-	EN ISO 22719	
Copper strip corrosion (3 hrs. at 50 °C)	Rating	Class 1		EN ISO 2160	
Distillation residue	% v/v	-	1,5	EN ISO 3405	
Smoke Point	mm	19	-	ASTM D1322	
Distillation	% (v/v) recovered at 210 °C	% v/v	-	90	EN ISO 3405
	% (v/v) recovered at 250 °C	% v/v	65	-	
	95% (v/v) recovered at 280 °C	% v/v	95	-	

Edition: 2019

Version: 1