

Property		Unit	Minimum	Maximum	Test method
Cetane number		-	70,0	-	EN ISO 5165
Density at 15 °C		kg/m³	765,0	800,0	EN ISO 3675
Flash Point		°C	>55,0	-	EN ISO 22719
Carbon residue on 10% distillation residue		% m/m	-	0,3	EN ISO 10370
Ash content		% m/m	-	0,0	EN ISO 6245
Water content		mg/kg	-	200	EN ISO 12937
Total contamination		mg/kg	-	24	EN ISO 12662
Copper strip corrosion (3 h at 50 °C)		Rating	Class 1		EN ISO 2160
Oxidation stability		g/m³	-	25	EN ISO 12205
		h	20	-	
Manganese content		mg/l	-	2,0	EN ISO 16136
Total aromatics		% m/m	-	1,1	EN ISO 12916
Sulfur content		mg/kg	-	5,0	EN ISO 20846
Lubricity, corrected wear scare diameter (wsd 1,4) at 60 °C		µm	-	400	EN ISO 12156-1
Viscosity at 40 °C		mm²/s	2,0	4,5	EN ISO 3104
	% (v/v) recovered at 250 °C	% v/v	-	<65	EN ISO 3405
Distillation	% (v/v) recovered at 350 °C	% v/v	85,0	-	
	95% (v/v) recovered at	°C	-	360	
CFPP	Summer*	°C	-	-10	EN 116
	Winter*	°C	-	-20	

Specification meets at least NEN-EN 15940

* Summer: March 1st - November 15th

** Winter: November 16th - Februari 28th

Edition: 2024

Version: 8